BSI-Inspectorate America 178 Mortland Road Searsport, Maine 04974 (207)548-6440



QUALITY CERTIFICATE

Vessel Customer

SHORE TANK NO. 1

SPRAGUE Operation **ANALYSIS** Port Date SEARSPORT, MAINE

April 13, 2005 SPRAGUE Terminal

Report Reference V-05-00623

SP/05/0412

Sample # 326561-3

Name of material being tested Description of sample source Samples Drawn by (company) Samples Tested by (company)

NO. 6 FUEL OIL 0.5%

EX. SHORE TANK NO. 1 AFTER DISCHARGE OF B 195 **BSI-INSPECTORATE BSI-INSPECTORATE**

Tests being Performed	Test method	Minimum Maximum	Sample Source
GRAVITY, API @ 60 F	ASTM D 4052		13.8
FLASH POINT, F	ASTM D 93		200 +
VISCOSITY, SSF @ 122 F	ASTM D 445/2161		95,2
POUR POINT, F	ASTM D 97		+37.4
WATER & SEDIMENT, % VOL.	ASTM D 1796		0.90
SULPHUR, % WT.	ASTM D 4294		0.487
ън, % wт.	ASTM D 482		0.098
TVÂNADIUM, PPM	AA/AE		9
SODIUM, PPM	AA/AE		20
BTU'S/POUND	CALCULATION		18,476
BTU'S/GALLON	CONVERSION		149,840
NITROGEN, % WT.	ASTM D 5762		0.2626
CARBON RESIDUE, % WT.	ASTM D 4530		8.16 2.13
ASPHALTENES, % WT.	IP-143		2.13
SPRAGUE PROVIDES THE ATTACHED INSPECTION RE	PORT/ANALYSIS		
REPRESENTING THE SPECIFICATIONS OF THE PROD	UCT AT THE SPRAGUE		
TERMINAL IN TANK ON THE DATE OF INSPECTION NO THIS ANALYSIS IS PROVIDED TO THE CUSTOMER FOR	OTED ON THE CERTIFICATE.		
ESTABLISHING THE INDEPENDENTLY VERIFIED PROD	OUCT SPECIFICATION ON		
A COMPOSITE BASIS IN SPRAGUES TERMINAL SHOP	E TANK AS NOTED ON THE		
CERTIFICATE. THE INSPECTION REPORT IS NOT TO E PURPOSE. SPRAGUE DISCLAIMS ANY LIABILITY FOR	BE USED FOR ANY OTHER THE DEADLICT AFTER DELIVERY		
BY SPRAGUE TO CUSTOMER, SPRAGUE DISCLAIMS /	ANY WARRANTY OF		
MERCHANIABILITY OR FITNESS FOR AN INTENDED USE	EXCEPT AS MAY BE SPECIFICALLY		
SET FORTH IN WRITING IN ANY CONTRACT OR TERM AND A BUYER OF PRODUCT, SPRAGUE ASSUMES NO L	S OF SALE BETWEEN SPHAGUE IABILITY FOR CLAIMS OR LOSSES		
THAT MAY ARISE FROM CUSTOMER'S USE OF THIS II	VSPECTION REPORT/ANALYSIS.		

DENNIS E. CURTIS

Inspectorate America Corp (Searsport, Me.)